

Whatcom County Fire Marshal's Office
Memorandum

To: Amy Keenan
From: Bill Hewett, Fire Inspector
Date: 7/22/08
Subject: LSS2007-00005

The Whatcom County Fire Marshal's Office requires the following condition(s) for the above permit.

1. Fire flow required. Fire flow shall be a minimum 500 gpm at 20 psi. Hydrants shall be located within 600 feet of the building areas.
2. Fire department access shall meet the requirements of the Whatcom County Development standards for roads. This includes at least one secondary access point due to the number of lots.
3. The proposal shall comply with all applicable codes and ordinances adopted by Whatcom County.